



**SANTA BARBARA CITY COLLEGE**

Facilities & Safety Committee Agenda

Thursday, March 23, 2023

11:00 am - 12:00 pm

[ZOOM](#)

- 1) Housekeeping Items
- 2) Review and approve [January 26, 2023](#) and [February 23, 2023](#) meeting minutes
- 3) Physical Education (PE) replacement update (Brian)
- 4) Relocation of the Faculty Resource Center (Brian)
- 5) Director of Facilities provide campus projects updates
  1. Radiology redesign replacement of equipment- grant funded - working on design with users and architect
  2. Replacement of PS Fume Hoods-JCI working on mechanical drawings-scheduled maintenance funding
  3. DM roof replacement- in progress to begin again during spring break
  4. Admin Chiller replacement- JCI working on mechanical drawings
  5. The Channels relocation to A180-bids going for Board approval 3/23/2023
  6. A182-Pod Casting Studio-Initial design phase-grant funded
  7. Repair of south wall of DM building-scheduled during summer break-scheduled maintenance funded
  8. Recarpet/painting/wall relocation CAD lab-complete-grant funded- furniture to be installed in June
  9. DM126-Repairing west facing wall in costume shop-in progress
  10. PS Roof Replacement - scheduled for summer 2023
  11. Autoclave replacement in EBS - Scheduled for May 2023
- 6) Director of Campus Safety to provide campus security incidents (Erik)

7) Storm Response

8) Risk Manager to provide update on Safety Items (Adrienne)

- Review campus injuries
- First aid
- Incident reports
- Safety concerns from Committee

9) Next Meeting is Apr 27, 2023

Adjourn 12pm

Admin Boiler pump. No Heat for A160-162 and A218 - A243

EBS First Floor Return Fan Motor. Air balancing off in building doors will be difficult to operate

OE AH2 motor. Heat for Transmission Shop and Drafting Labs

LFC HP6 motor. Several other units running but may affect desired comfort range

PS and WCC main panel surge protectors. Doesn't affect operation but makes equipment more susceptible to power surge or failure. BLUM electric has ordered both replacement units this morning.

WCC Several areas where lighting controls are affected.

BC Mechanical systems took several attempts to restart. Maybe slightly cooler in the building this morning but all systems are functioning normally.

Currently Assessing IDC and SS, Campus Portable Buildings.

Library systems normal

Campus Center system normal

Humanities system normal

Campus Store no reported issues

Orfalea Learning Center. Not affected by campus event

Cosmo. Not affected by campus event